

To confirm the validity of this certificate, please contact the registered Gas Engineer on 08 5500 5500 or www.gassaferegister.co.uk

08 5500 or www.gassaferegister.co.uk



LANDLORD/HOMEOWNER GAS SAFETY RECORD

This form allows for the recording of results of checks as defined by the Gas Safety (Installation and Use) Regulations. Information recorded on this form does not confirm that the installation was installed by a Gas Safe registered business or that the installation complies with relevant Building Regulations. Chimney/flue outlets were visually checked for adequate evacuation of combustion products. A detailed internal inspection has not been undertaken.

DETAILS OF REGISTERED BUSINESS

Frank-K
Gas Safe Reg. No: 527466
21 Millbank Road,
Munlochy, IV8 8NL
Tel. No: 07766 604 556

DETAILS OF REGISTERED BUSINESS

Job Address: 155g Church 11
St Dunels ASS
15th August
Tel. No:
Is Accommodation Rented? (Y/N)
No. Of Appliances Tested: 2

LANDLORD/AGENT ADDRESS

Name: Susan
Address:
Tel. No:
No. Of Appliances Tested: 2

Gas Installation Pipework

Satisfactory Visual Condition (Y/N)

Emergency Control Accessible (Y/N)

Satisfactory Gas Tightness Test (Y/N)

Equipment Potential Bonding Satisfactory (Y/N)

Appliance Details

	Appliance Location	Appliance Make	Appliance Model	Appliance Type	Type of Flue (OF/RS/FL)	Landlords Appliance (Y/N)	Appliance Inspected (Y/N)
1	Cupboard	Wick	Wicca 36ME	Boiler	RS	Y	Y
2	Under	Sing		Hot	R	Y	Y
3							
4							
5							

Inspection Details

	Operating Pressure in mbar and or Heat Input in kW/Btu/h	Are Safety Devices Working? (Y/N)	Satisfactory Ventilation? (Y/N)	Flue Visual Condition (Pass/Fail/NA)	Flue Performance Checks (Pass/Fail/NA)	Combustion Analyser Reading		Appliance Serviced (Y/N)	Appliance Safe To Use (Y/N)	CO Alarm	
						CO: CO2 Ratio	CO PPM			Approved CO Alarm Fitted? (Y/N)	Does The CO Alarm Work? (Y/N)
1	35bar	Y	Y	Pass	MT	0.017	161	Y	Y	Y	Y
2		Y	Y	MT	MT			Y	Y		
3											
4											
5											

Defect(s) Identified

Warning Advice Issued? (Y/N)

Work Carried Out

Details Of Work Required

Received By:

Print Name:

Issued By: Pat Dunn

Signature: [Signature]

ID Card No: 5983087

Date: 14/2/22

The Next Gas Safety Check Must Be Completed By: 14/2/22